شركة بشائر البناء للمقاولات
Bashaer Al-Benaa Contracting Company

ECEC شركة الشرق للاستشارات الهندسية

الهيئة السعودية للسياحة
SAUDI TOURISM AUTHORITY

MATERIAL INSPECTION REPORT

MIR - Area - Site - Disc
Serial /BBC-ECE-AR-MIR-08-R01

Description of Material for Inspection :-	Reference Documents / Attachments: Material
CONCRETE BLOCK	Submittal No.:
	BBC-ECE-AR-MAS-01-R01
	Spec./Dwg. Ref.:
	BOQ Reference: _Electrical works
	Test/Mill Certificates

Item / Qty. Req'd.	Qty. Delivered	Qty. Rejected	Total Quantity	Attachments:
BLOCK 20 CM	500			Copy of the Packing List :- ✓
				Copy of Purchase Order :- ✗

S

Date of Material Delivery: 07/01/2023

Report:

- SAMPLE SHOULD BE APPROVED AS PER CLIENT RECOMMENDATION
- SAMPLE NOT YET APPROVED & HOW DELIVERD QTY AT SITE.
- IF INSULATED BLOCK MEET THE REQUREMENT OF DATA CENTER & CLIENT RECOMMENDATION THAN AFTER SHOULD BE ACCEPTABLE.
- SHOULD PROVIDE APPROVED SAMPLE & TECHNICAL DATA BEFORE START INSTALLATION.
-

PM.Eng.	Eng.Ahmed Medht	Signature:	
TEC.Eng.	MOHAMED ELHAWARY	Signature:	
D.CONTROL	AHMED GAMAL	Signature:	

شركة بشائر البناء للمقاولات
Bashaer Al Benaa Contracting Co.
Date: 09/01/2023
Date: 09/01/2023
Date: 09/01/2023

Inspection Status:

☐ Approved / Proceed

☑ Approved with comments ☐ Rejected

CONSULANT Eng: AMIR KHAN — Signature: — Date: 9/1/2023.

PM.CONSULANT Eng: _ — Signature: — Date: —

CLIENT Representative: _ — Signature: — Date: 9-1-23

Material Release / Hold / Quarantined:

Distribution	Inspector ☐	AM ☐	AAM ☐	QA/QC ☐	PCS Manager ☐	Contractor ☐

Area:

Site:

Discipline:

9/1/2023

9.1.23